


CONTROL PANEL



Standard components:

- 1- 16 x 14 x 7 NEMA 4X polycarbonate enclosure.
- 2- IEC motor contactor.
- 3- MCC B for shorcut.
- 4- Alternator.
- 5- Green Pump run indicator lights.
- 6- Alarm/Control CB.
- 7- Float switch terminal block angled for ease of field installation.
- 8- Input power terminal block angled for ease of field installation.
- 9- Ground lugs.
- 10- HOA(Hand/Off/Auto) switches.

Standard Alarm Package:

- 11- High alarm relay for dry contacts.
- 12- Indicator light for visual check.
- 13- Sonalert audible alarm.
- 14- Exterior alarm test with silence.
- 15- Horn silence relay.

GENERAL NOTES

BASIN DIAMETER (A)	
BASIN DEPTH (B)	
PHASE	
VOLTAGE	
PUMP MODEL	
FLOW (GPM)	
TDH (FEET)	
HP	
RPM	
DISCHARGE	
VALVEBOX DIMS	36′′ X 40′′X 40′′

NOTES:

PLEASE CONTACT WASTEWATER SOLUTIONS LLC ARTURO GARCIA (954)-483-9269

Email: Arturo@WWS-LLC.com

DUPLEX EJECTOR WITH VALVEBOX HARD PIPED STATION CONCRETE BASIN

Revision notes:					
Rev:	Date:	Notes:			
A 1	19/07/21	PROJECT			

Drawn by:	Project:
C.Grajeda	WASTEWATER
Client:	Drawing Title:
	DUPLEX EJECTOR WITH VALVEBOX HP
	11

