


CONTROL PANEL



Standard components:

- 1- 16 x 14 x 7 NEMA 4X polycarbonate enclosure.
- 2- IEC motor contactor.
- 3- MCC B for shorcut.
- 4- Alternator.
- 5- Green Pump run indicator lights.
- 6- Alarm/Control CB.
- 7- Float switch terminal block angled for ease of field installation.
- 8- Input power terminal block angled for ease of field installation.
- 9- Ground lugs.
- 10- HOA(Hand/Off/Auto) switches.

Standard Alarm Package:

- 11- High alarm relay for dry contacts.
- 12- Indicator light for visual check.
- 13- Sonalert audible alarm.
- 14- Exterior alarm test with silence.
- 15- Horn silence relay.

GENERAL NOTES

	BASIN DIAMETER (A)
	BASIN DEPTH (B)
	PHASE
	VOLTAGE
	PUMP MODEL
	FLOW (GPM)
	TDH (FEET)
	HP
	RPM
	DISCHARGE
36′′ X 40′′X 40′′	VALVEBOX DIMS

NOTES:

PLEASE CONTACT
WASTEWATER SOLUTIONS LLC
ARTURO GARCIA
(954)-483-9269

Email: Arturo@WWS-LLC.com

DUPLEX EJECTOR WITH VALVEBOX HARD PIPED STATION FIBERGLASS BASIN

ision notes:			
: Date:	Notes:		
19/07/21	PROJECT		

Drawn by:	Project:	D
C.Grajeda	WASTEWATER	1
		S
Client:	Drawing Title:	x
	WWS DUPLEX EJECTOR WITH VALVEBOX	HP R

